

1st Quarter 2023 Sampling Results for Emerging Contaminants

Plant/Well	1,4-Dioxane (ppb)	PFOS (ppt)	PFOA (ppt)	PFBS** (ppt)	PFHpA** (ppt)	PFHxS** (ppt)	PFNA** (ppt)	Comments
<u>Waterworks Site</u>								
Well No. 7	ND	ND	ND	ND	ND	ND	ND	2 sample results - awaiting third sample results
<u>Rockaway Avenue Site</u>								
Well No. 8	1.4	3.6	5.0	ND	ND	ND	ND	
Well No. 12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2023.
<u>Wilson Street Site</u>								
Well No. 9	0.40	4.2	2.3	ND	ND	1.8	5.7	
<u>Clinton Road Site</u>								
Well No. 10	ND	ND	ND	ND	ND	ND	ND	3 sample results
Well No. 11	ND	ND	ND	ND	ND	ND	ND	3 sample results
<u>Country Club Site</u>								
Well No. 13	0.77	10.0	6.7	ND	2.8	4.5	16.1	
Well No. 14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2023.
<u>Hilton Park Site</u>								
Well No. 15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2023.
Well No. 16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2023.

\*\* There is no maximum contaminant level associated with these additional compounds as they are currently not regulated.

Legend:

PFOA:	Perfluoroctanoic acid	**PFHxS: Perfluorohexanesulfonic acid	ppb: parts per billion
PFOS:	Perfluoroctanesulfonic acid	**PFNA: Perfluorononanoic acid	ppt: parts per trillion
**PFBS:	Perfluorobutanesulfonic acid	MCL: Maximum Contaminant Level	ND: Sample result was below detectable limit
**PFHpA:	Perfluoroheptanoic acid		