

2nd Quarter 2022 Sampling Results for Emerging Contaminants

Plant/Well	1,4-Dioxane (ppb)	PFOS (ppt)	PFOA (ppt)	PFBS** (ppt)	PFHpA** (ppt)	PFHxS** (ppt)	PFNA** (ppt)	Comments
<u>Waterworks Site</u>								
Well No. 7	ND	ND	ND	ND	ND	ND	ND	
<u>Rockaway Avenue Site</u>								
Well No. 8	1.10	3.0	3.9	ND	ND	ND	ND	
Well No. 12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in Second Quarter 2022.
<u>Wilson Street Site</u>								
Well No. 9	0.42	2.4	ND	ND	ND	ND	3.5	
<u>Clinton Road Site</u>								
Well No. 10	ND	ND	ND	ND	ND	ND	ND	
Well No. 11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in Second Quarter 2022. <sup>(1)</sup>
<u>Country Club Site</u>								
Well No. 13	0.84	10.9	4.7	ND	2.5	3.9	15.0	
Well No. 14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in Second Quarter 2022.
<u>Hilton Park Site</u>								
Well No. 15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in Second Quarter 2022.
Well No. 16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in Second Quarter 2022.

\*\* There is no maximum contaminant level associated with these additional compounds as they are currently not regulated.

<sup>(1)</sup> Well No. 11 was approved for use in late June but was not placed in service until July.

Legend:

PFOA:	Perfluorooctanoic acid	**PFHxS: Perfluorohexanesulfonic acid	ppb: parts per billion
PFOS:	Perfluorooctanesulfonic acid	**PFNA: Perfluorononanoic acid	ppt: parts per trillion
**PFBS:	Perfluorobutanesulfonic acid	MCL: Maximum Contaminant Level	ND: Sample result was below detectable limit
**PFHpA:	Perfluoroheptanoic acid		