

1st Quarter 2022 Sampling Results for Emerging Contaminants

Plant/Well	1,4-Dioxane (ppb)	PFOS (ppt)	PFOA (ppt)	PFBS** (ppt)	PFHpA** (ppt)	PFHxS** (ppt)	PFNA** (ppt)	Comments
<u>Waterworks Site</u>								
Well No. 7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.
<u>Rockaway Avenue Site</u>								
Well No. 8	0.95	3.7	4.8	ND	ND	ND	ND	
Well No. 12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.
<u>Wilson Street Site</u>								
Well No. 9	0.39	1.5 ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	4 ⁽¹⁾	
<u>Clinton Road Site</u>								
Well No. 10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.
Well No. 11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.
<u>Country Club Site</u>								
Well No. 13	0.79	12.2	5.6	ND	2.8	4.4	18.5	
Well No. 14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.
<u>Hilton Park Site</u>								
Well No. 15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.
Well No. 16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in First Quarter 2022.

** There is no maximum contaminant level associated with these additional compounds as they are currently not regulated.

⁽¹⁾ Samples taken on 1/26/2022 were never returned by lab. Samples taken on 3/25/2022 are pending.

Results shown are from 4th Quarter 2021.

Legend:

PFOA:	Perfluoroctanoic acid	**PFHxS: Perfluorohexanesulfonic acid	ppb: parts per billion
PFOS:	Perfluoroctanesulfonic acid	**PFNA: Perfluorononanoic acid	ppt: parts per trillion
**PFBS:	Perfluorobutanesulfonic acid	MCL: Maximum Contaminant Level	ND: Sample result was below detectable limit
**PFHpA:	Perfluoroheptanoic acid		