

1st Quarter 2021 Sampling Results for Emerging Contaminants

Plant/Well	1,4-Dioxane (ppb)	PFOS (ppt)	PFOA (ppt)	PFBS** (ppt)	PFHpA** (ppt)	PFHxS** (ppt)	PFNA** (ppt)	Comments
<u>Waterworks Site</u>								
Well No. 7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
<u>Rockaway Avenue Site</u>								
Well No. 8	0.87	3.8	5.5	ND	ND	ND	ND	
Well No. 12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
<u>Wilson Street Site</u>								
Well No. 9	0.37	2.2	ND	ND	ND	ND	3.4	
<u>Clinton Road Site</u>								
Well No. 10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
Well No. 11	0.98	10.6	9.6	ND	5.2	5.6	5.3	
<u>Country Club Site</u>								
Well No. 13	0.85	7.9	4.3	ND	2.1	3.0	16.1	
Well No. 14	1.5	22.4	8.4	ND	5.8	7.4	20.0	Taken out of Service after sampling results.
<u>Hilton Park Site</u>								
Well No. 15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
Well No. 16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021

** There is no maximum contaminant level associated with these additional compounds as they are currently not regulated.

Legend:

PFOA:	Perfluoroctanoic acid	**PFHxS: Perfluorohexanesulfonic acid	ppb: parts per billion
PFOS:	Perfluoroctanesulfonic acid	**PFNA: Perfluorononanoic acid	ppt: parts per trillion
**PFBS:	Perfluorobutanesulfonic acid	MCL: Maximum Contaminant Level	ND: Sample result was below detectable limit
**PFHpA:	Perfluorohethanoic acid		